

0136


Date: 9 September 1982

Memorandum for the Record

From: Ms. Betz, Quality Control Lab., Environmental Section, NREAB, BMaintDiv

Subj: Rifle Range Water Treatment Plant Sampling on 5 April 1982; Results of

1. A resampling was requested of the Rifle Range Water Treatment Plant wells and finished water, because Jennings found 1000ppb of PCB in the 18 March 1982 finished water sample. LANTDIV split the samples, half to Jennings and half to NAVENENVSA for quality control check. The one to NAVENENVSA leaked out during transit.
2. Jennings did not find any PCB in their portion of the 5 April 1982 samples.

  
Elizabeth A. Betz  
Supervisory Chemist

CLW

0000000643